

SOMERSET RARITAN VALLEY SEWERAGE AUTHORITY

ADDENDUM NO. 2 TO FURNISHING AND DELIVERY OF POLYMER CONTRACT NO. A-19-1 (REBID)

ADDENDUM NO. 2

This Addendum shall be part of the Contract Documents for the Somerset Raritan Valley Sewerage Authority, Furnishing and Delivery of Polymer, Contract No. A-19-1 (Rebid) as provided in the Instructions to Bidder.

Acknowledge receipt of this Addendum indicating so in the Bid Form. Failure to do so will subject the Bidder to disqualification.

SPECIFICATIONS REVISIONS

Revision #1: Section P-Forms, Page 9:

The following sentence in **bold** shall be added:

“Number of days required for shipment after placement of deliver request: 2 days. **Failure to provide deliveries within 2 days of the deliver request will result in a cancellation of this Contract, at the sole discretion of the Somerset Raritan Valley Sewerage Authority.**”

Revision #2: Specification Page TS-2:

Paragraph 4, C: Add the following sentence in **bold** to the end of this paragraph: “**The bidder, with the assistance of the Authority staff, shall determine the starting weight of the drum(s) of polymer prior to the start of the test. The Authority will provide the drum scale and all related equipment.**”

Revision #3: Specification Page TS-2:

Paragraph 4, G: The following sentence in **bold** shall be added:

“Upon completion of the four-hour trial test, **the bidder, with the assistance of the Authority staff, shall determine the ending weight of the drum(s) of polymer. The bidder shall remove all equipment and materials from the Authority’s property within five (5) working days or bid shall not be considered at the time of the bid opening.**”

Revision #4: Specification Page TS-3:

Add the following paragraph 4, J:

“J. The polymer test shall not cause any problems or difficulties with the Authority’s dosing/feed system or any of its equipment, or any problems connected to Authority’s belt filter presses, as determined solely by the Authority staff. Any operational problems related to the test polymer shall result in the disqualification of the bid.”

Revision #5: Specification Page TS-4:

Add the following paragraph 9, C:

“C. At any time during this Contract period, as determined by the Authority staff that there are any performance issues as compared to the results of the four-hour trial test, shall result in the termination of this Contract.”

Revision #6: Specification Page TS-4:

Add the following paragraph 9, D:

“D. At any time during this Contract period, as determined by the Authority staff that there are any storage and/or equipment issues (such as the unintentional destabilization of the product), shall result in the termination of this Contract.”

END OF ADDENDUM NO. 2